




# Fixture Specification

MODEL #: **DFCV**  
 STYLE / LAMP / LAMP / WATTAGE / KELVIN / BALLAST / FINISH / LENS / ACCESSORIES / SIZE / COMPLIANCE  
 QTY TYPE DETAIL

PROJECT : \_\_\_\_\_ TYPE : \_\_\_\_\_ NOTE : \_\_\_\_\_



### Light Source

Type	Twin Tube		Quad		Triple		Linear						Length	Height	Depth					
	13	18	24	36	40	55	18	26	32	42	T8					T5 HO				
Wattage	3	2	1	1	-	-	3	-	-	-	15	17	25	32	24	39	54	24-1/2"	4-3/4"	4-1/2"
Quantity	-	-	2	-	1	1	-	-	-	-	-	1/2	-	-	1	-	-	36-1/2"	4-3/4"	4-1/2"
	-	-	-	2	-	-	-	-	-	-	-	-	1/2	-	-	1	-	48-1/2"	4-3/4"	4-1/2"

### Standard Features

<b>BASE</b>	Aluminum Construction Mounts to Electric Box with Center Nipple	<b>FINISH</b>	Chrome	<b>LENS</b>	White Fluted Acrylic UV Stabilized Non Yellowing
<b>LAMP</b>	Twin and Quad -2700K Linear - 4100K	<b>TECHNOLOGY</b>	Electronic Ballast Normal Power Factor 120V-60Hz AC UL Listed Damp Location		

### Special options

Please Note: Standard Features May Change if Fixtures are Ordered with Special Option(s).

<b>BALLAST</b>	<input type="checkbox"/> DV 120/277 <input type="checkbox"/> EBD Dimmable <input type="checkbox"/> EMG Emergency <input type="checkbox"/> HPF High Power Factor <input type="checkbox"/> V 277 Volt	<b>FINISH</b>	<input type="checkbox"/> FBR Brass	<b>COMPLIANCE</b>	<input type="checkbox"/> ES Energy Star <input type="checkbox"/> MIA Made In America
<b>KELVIN</b>	<input type="checkbox"/> 3500K <input type="checkbox"/> 4100K	<b>TECHNOLOGY</b>	<input type="checkbox"/> GU24 ( Energy Star Compliant Component ) <input type="checkbox"/> LED <input type="checkbox"/> Occupancy Sensor		

For Additional Accessories and Options Visit [www.aslighting.com](http://www.aslighting.com)

ASL  
25 Twelfth Street  
Brooklyn, NY 11215-3820

Toll Free  
Phone: 800-369-1101  
Fax: 800-552-3465

Local  
Phone: 718-369-1100  
Fax: 718-369-1105

Online  
email: [info@aslighting.com](mailto:info@aslighting.com)  
visit: [www.aslighting.com](http://www.aslighting.com)



© copyright 2008 by American Scientific Lighting Corp. All rights reserved.

**DFCV**